



City of Pittsburg, KS
Proposal #2024-002
Annual Fixed Location Generator
Inspection & Maintenance
Bid Date: 12/3/2024

ADDENDUM NO. 1
November 25th, 2024

Clarifications:

This Addendum has been prepared and issued to answer a question submitted from vendors / contractors with regard to the bid for Annual Fixed Location Generator Inspection & Maintenance.

Fire Station 1 and Law Enforcement Center generator sets need to be load bank tested and records kept to meet NFPA 110 standards. All other generator sets load bank tested for 2 hours.

Acknowledgement of Addenda:

To acknowledge receipt of this Addenda, please include it as an attachment to your bid proposal.

THE CITY OF PITTSBURG