



City of Pittsburg, KS
Proposal #2024-002
Annual Fixed Location Generator
Inspection & Maintenance
Bid Date: 12/3/2024

ADDENDUM NO. 2
November 26th, 2024

Clarifications:

This Addendum has been prepared and issued to answer a question submitted from vendors / contractors with regard to the bid for Annual Fixed Location Generator Inspection & Maintenance.

All generators will need to be load bank tested each year. The two under NFPA 110 will follow that standard. The others will be exercised annually with supplemental loads at not less than 50 percent of the nameplate kW rating for 30 continuous minutes and at not less than 75 percent of the nameplate kW rating for 1 continuous hour for a total test duration of not less than 1.5 continuous hours.”

Also, the scheduled maintenance does NOT include any oil or filter changes. Bid is for the electrical side and controls only.

Acknowledgement of Addenda:

To acknowledge receipt of this Addenda, please include it as an attachment to your bid proposal.

THE CITY OF PITTSBURG